


CERTIFICATE

Certified Passive House Component

Component-ID 1504sp03 valid until 31st December 2021

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany



Category: **Spacer for low-E-glazing**

Manufacturer: **ROLLTECH A/S,
Hjorring,
Denmark**

Product name: **CHROMATECH ultra S**

This certificate was awarded based on the following criteria:

Depending on the climatic region, the spacer prevents high surface temperatures, which can cause mould. At least 3 out of the 7 reference frames fulfilled the spacer hygiene criteria for the relevant climatic region.

Hygiene $f_{Rsi} \geq 0.70$

The specific resistance of the spacer's edges is greater than the climate-independent minimum requirement.

Efficiency $R_E = 3.40 \text{ m K/W} \geq 1.50 \text{ m K/W}$

| Type |
|------------------------------|
| Plastic with stainless steel |
| Height Box 2 |
| 6.85 mm |
| Thermal conductivity Box 2 |
| 0.320 W/(m K) |



cool, temperate climate



**CERTIFIED
COMPONENT**

Passive House Institute

Passive House
efficiency class

phE

phD

phC

phB

phA

phA+

ROLLTECH A/S

Johs. E. Rasmussens Vej 12, 9800 Hjørring, Denmark

☎ +45 96 23 33 43 | ✉ sales@rolltech.dk | 🌐 <http://www.rolltech.dk> |

Description

Spacer Bar in stainless steel (0.10 mm combined with a special Plastic Top).

Spacer height: 6.85 mm

Thermal conductivity: 0.320 W/(m K) (WA-17/1 measured)

Available spacer widths: 8, 10, 12, 13, 14, 15, 16, 18, 20, 22 and 24 mm

| Appropriate secondary seal | Specific edge resistance R_E | Efficiency class |
|----------------------------|--------------------------------|------------------|
| Polysulfide | 3.40 m K/W | phB |
| Polyurethane | 3.40 m K/W | phB |
| Silicone | 3.60 m K/W | phB |

Explanation




































Spacers are categorized into different efficiency classes based on the resistance of their edges R_E . A secondary polysulfide sealant is typically used, unless the spacer is not approved for polysulfide. A detailed report with the calculations is available from either the manufacturer or the Passive House Institute.

The Passive House Institute has defined global component requirements for seven climate regions. In principle, components that have been certified for climates with higher requirements can also be used in climates with lower requirements. This may be economically advantageous.

Use in PHPP:

If individually calculated values are not available then the thermal bridge loss coefficient specified in this document can be used. In this case, the appropriate reference frame must be selected and a 10% safety margin should be applied.

Further information regarding certification is available on www.passivehouse.com and www.passipedia.org.

| Reference frames calculated with Polysulfide | | | | | |
|--|---|---|---|---|---|
| Climate | Arctic | Cool | Cool temperate ✓ | Warm temperate ✓ | Warm ✓ |
| Glass | Quadruple | Triple | Triple | Triple | Double |
| Glass package | 4/12/3/12/3/12/4 | 6/18/2/18/6 | 6/16/6/16/6 | 6/16/6/16/6 | 6/16/6 |
| Glass U-value | 0.35 W/(m ² K) | 0.52 W/(m ² K) | 0.70 W/(m ² K) | 0.70 W/(m ² K) | 1.20 W/(m ² K) |
| Timber-aluminium integral frame |  |  |  |  |  |
| U_f [W/(m ² K)] | 0.48 | 0.62 | 0.73 | 0.87 | 1.03 |
| Ψ_g [W/(m K)] | 0.038 | 0.041 | 0.040 | 0.039 | 0.043 |
| f_{Rsi} [-] | 0.77 | 0.73 | 0.70 ✓ | 0.68 ✓ | 0.58 ✓ |
| Timber-aluminium |  |  |  |  |  |
| U_f [W/(m ² K)] | 0.54 | 0.57 | 0.75 | 0.97 | 1.19 |
| Ψ_g [W/(m K)] | 0.041 | 0.043 | 0.043 | 0.042 | 0.048 |
| f_{Rsi} [-] | 0.73 | 0.71 | 0.66 | 0.64 | 0.52 |
| Timber |  |  |  |  |  |
| U_f [W/(m ² K)] | 0.51 | 0.53 | 0.78 | 0.86 | 0.99 |
| Ψ_g [W/(m K)] | 0.036 | 0.040 | 0.039 | 0.039 | 0.043 |
| f_{Rsi} [-] | 0.75 | 0.74 | 0.71 ✓ | 0.71 ✓ | 0.60 ✓ |
| Vinyl |  |  |  |  |  |
| U_f [W/(m ² K)] | 0.70 | 0.75 | 0.82 | 1.02 | 1.16 |
| Ψ_g [W/(m K)] | 0.041 | 0.044 | 0.044 | 0.450 | 0.500 |
| f_{Rsi} [-] | 0.76 | 0.73 | 0.71 ✓ | 0.70 ✓ | 0.61 ✓ |
| Aluminium |  |  |  |  |  |
| U_f [W/(m ² K)] | 0.60 | 0.61 | 0.71 | 0.73 | 1.17 |
| Ψ_g [W/(m K)] | 0.044 | 0.048 | 0.049 | 0.049 | 0.055 |
| f_{Rsi} [-] | 0.77 | 0.76 ✓ | 0.74 ✓ | 0.74 ✓ | 0.61 ✓ |
| Curtain wall timber |  |  |  |  |  |
| U_f [W/(m ² K)] | 0.60 | 0.65 | 0.66 | 0.71 | 1.11 |
| Ψ_g [W/(m K)] | 0.057 | 0.056 | 0.058 | 0.058 | 0.070 |
| f_{Rsi} [-] | 0.71 | 0.70 | 0.67 | 0.67 ✓ | 0.53 |
| Curtain wall aluminium |  |  |  |  |  |
| U_f [W/(m ² K)] | 0.67 | 0.73 | 0.75 | 0.79 | 1.33 |
| Ψ_g [W/(m K)] | 0.067 | 0.067 | 0.070 | 0.070 | 0.095 |
| f_{Rsi} [-] | 0.80 ✓ | 0.78 ✓ | 0.76 ✓ | 0.76 ✓ | 0.64 ✓ |

